

**PACIFIC LUTHERAN UNIVERSITY
 CAMPUS FIRE SAFETY RIGHT -to- KNOW
 2019 Fire Log**

<u>Residential Building</u>	<u>Date Fire Reported</u>	<u>Time Fire Reported</u>	<u>Number of Fires</u>	<u>Location of Fire</u>	<u>Cause of Fire</u>	<u>Number of Injuries that Required Treatment at a Medical Facility</u>	<u>Number of Deaths Related to Fire</u>	<u>Value of Property Damage Caused by Fire</u>	<u>Case Number</u>
South Hall	3/22/2019	5:48 PM	1	residence hall kitchen, room 036	Oil overheated in skillet while cooking	0	0	NA	1

**PACIFIC LUTHERAN UNIVERSITY
 CAMPUS FIRE SAFETY RIGHT -to- KNOW
 2018 Fire Statistics: Log**

<u>Residential Building</u>	<u>Date Fire Reported</u>	<u>Time Fire Reported</u>	<u>Number of Fires</u>	<u>Location of Fire</u>	<u>Cause of Fire</u>	<u>Number of Injuries that Required Treatment at a Medical Facility</u>	<u>Number of Deaths Related to Fire</u>	<u>Value of Property Damage Caused by Fire</u>	<u>Case Number</u>
None	NA	NA	NA	NA	NA	NA	NA	NA	NA

**PACIFIC LUTHERAN UNIVERSITY
 CAMPUS FIRE SAFETY RIGHT -to- KNOW
 2017 Fire Statistics: Log**

<u>Residential Building</u>	<u>Date Fire Reported</u>	<u>Time Fire Reported</u>	<u>Number of Fires</u>	<u>Location of Fire</u>	<u>Cause of Fire</u>	<u>Number of Injuries that Required Treatment at a Medical Facility</u>	<u>Number of Deaths Related to Fire</u>	<u>Value of Property Damage Caused by Fire</u>	<u>Case Number</u>
Tingelstad Hall	11/3/2017	1:00 PM	1	Room 814	Combustible material (i.e. cardboard boxes) placed on top of electrical stove element that was inadvertently turned on caused the fire.	0	0	\$89,500	1

**PACIFIC LUTHERAN UNIVERSITY
CAMPUS FIRE SAFETY RIGHT -to- KNOW
2016 Fire Statistics: Log**

<u>Residential Building</u>	<u>Date Fire Reported</u>	<u>Time Fire Reported</u>	<u>Number of Fires</u>	<u>Location of Fire</u>	<u>Cause of Fire</u>	<u>Number of Injuries that Required Treatment at a Medical Facility</u>	<u>Number of Deaths Related to Fire</u>	<u>Value of Property Damage Caused by Fire</u>	<u>Case Number</u>
South Hall	6/8/2016	10:40am	1	Room 220	Smoldering ember from solder ignited construction debris.. Fire Watch In Place	0	0	\$0.00	1

**PACIFIC LUTHERAN UNIVERSITY
CAMPUS FIRE SAFETY RIGHT -to- KNOW
2015 Fire Statistics: Log**

<u>Residential Building</u>	<u>Date Fire Reported</u>	<u>Time Fire Reported</u>	<u>Number of Fires</u>	<u>Location of Fire</u>	<u>Cause of Fire</u>	<u>Number of Injuries that Required Treatment at a Medical Facility</u>	<u>Number of Deaths Related to Fire</u>	<u>Value of Property Damage Caused by Fire</u>	<u>Case Number</u>
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A