

FACILITY ACTION PLAN

FACILITY Hauge Administration		SITE ID	DATE
CURRENT ENERGY USE INDEX (EUI) 52 kBtu/Sq Ft 19kWh/Sq Ft	TARGET EUI 50 kBtu/Sq Ft 18 kWh/Sq Ft	AVERAGE EUI (BENCHMARK) FOR THE FACILITY TYPE 106.64 kBtu/Sq Ft 25.86 kWh/Sq Ft	
FACILITY LIASON(S)	FACILITY RCM TEAM MEMBERS (NAME AND POSITION) 1. Christine Cooley – Sustainability Coordinator		

POTENTIAL CONSERVATION MEASURES, OPERATIONAL IMPROVEMENTS, OR MODIFICATIONS	
MEASURE SUMMARY <i>(LIST HIGH PRIORITY MEASURES FIRST)</i>	FOLLOW UP BY <i>(PERSON AND DATE)</i>
1. Temperature Set Point Policy	
2.	
3.	
4.	
5.	
6.	
7.	
8.	
9.	
10.	

DETAILED MEASURE DESCRIPTIONS / NEEDS (OPTIONAL)	
DESCRIPTION	INSERT PHOTO HERE (OPTIONAL)
1. Temperature Set Point Policy will allow hallways to be programmed. Electric heat, rooms have baseboard heating, needs heating systems upgrade for rooms, but hallways can be programmed immediately.	RESOURCES REQUIRED ACCOUNTABLE PARTY SUPPORT STAFF SCHEDULE FOR COMPLETION
2. Replace the windows with high performance glazing to reduce heating and cooling loads. (4x88 5'x6' windows, 8x88 2'x2' windows and 8x88 2'x2' operable windows.	RESOURCES REQUIRED ACCOUNTABLE PARTY SUPPORT STAFF SCHEDULE FOR COMPLETION
3.	RESOURCES REQUIRED ACCOUNTABLE PARTY SUPPORT STAFF SCHEDULE FOR COMPLETION